

DATA CENTER ENERGY SAVINGS

WHITE PAPER

# The Biggest Opportunity for Data Center Energy Savings

by Ian Seaton



CHATSWORTH  
PRODUCTS, INC.

**800-834-4969**

[techsupport@chatsworth.com](mailto:techsupport@chatsworth.com)  
[www.chatsworth.com](http://www.chatsworth.com)

©2009 Chatsworth Products, Inc. All rights reserved. CPI, CPI Passive Cooling, Saf-T-Grip, Seismic Frame, SlimFrame and MegaFrame are federally registered trademarks of Chatsworth Products, Inc. Cube-IT Plus, Evolution, OnTrac, QuadraRack, Simply Efficient and TeraFrame are trademarks of Chatsworth Products, Inc. All other trademarks belong to their respective companies. MKT-60020-397 Rev.2 03/09

It is time to finally get over the misconceptions generated by the loud and misleading rhetoric regarding the superior efficiencies of close-coupled and liquid cooled server cabinet solutions, as well as the supposed limits on power densities that can be effectively cooled by air. Passive air cooling can successfully dissipate as much heat as can be generated by commercial servers that can actually fit in a 42-45 U cabinet, and in fact more than most close-coupled and liquid-cooled solutions. In addition, air-cooled solutions that rely on complete isolation between supply air and return air are more efficient than most close-coupled systems and provide access to lower data center cooling costs.

### Meeting the Higher Heat Density Challenge

The old conventional wisdom regarding some ceiling on how much heat could be effectively cooled by air is based on an accurate assessment of the innate inefficiencies of standard hot aisle/at cold aisle data centers and a poor understanding of the natural forces that can be harnessed to remove heat from a cabinet. That conventional wisdom has typically placed the ceiling at somewhere around 6 kW per cabinet. In addition, that conventional wisdom was based on an accurate understanding of the fixed relationship between airflow, heat dissipation and temperature rise ( $CFM = 3.1W/\Delta T$ ) in the context of a standard hot aisle/cold aisle data center where there is a dependency relationship between the volume of cold air delivered through a proximate perforated floor tile and a cabinet server heat load, plus the presence of heated server exhaust air (return air) in the room. The practical limits to how much air you can push a through a perforated floor tile and the looming presence of that heated return air conspire to limit how much can be cooled in any particular cabinet.

Removing these constraints thus opens the door to higher power/heat densities that could potentially be cooled by air. In a data center where the cabinets function as a complete isolation barrier between supply air and return air, these constraints are removed. This isolation is accomplished by a combination of accessories such as blanking filler panels, equipment mounting area perimeter sealing air dams and floor-tile cut-out brush seal grommets, along with a system to remove the return air from the room into a suspended ceiling return air space. Such a system would include a solid rear cabinet door with gasket seal and a vertical exhaust duct running between the cabinet and the suspended ceiling. In this construction, there is no longer any dependency on how much air can be pushed through a single perforated floor tile and there is no heated air anywhere in the room to prevent the use of cold air delivered anywhere into that room. As heat densities increase beyond the level that could practically be achieved by under-floor air delivery without creating extra-wide cold aisles, then the access floor can be eliminated all together and the room can be flooded with high volumes of cold air through wall grates or from overhead.

With the availability of a theoretically infinite cooling capacity, the remaining constraint revolves around effectively removing the heat from the cabinet. While it is not particularly prudent to reveal all the intellectual property in this solution until all the patents are finally issued, suffice to say that Chatsworth Products, Inc. (CPI) Passive Cooling® Solutions involve specific geometries that exploit the forces of the Bernoulli Principle (inverse relationship between velocity and pressure) to create forces within the cabinet to remove high volumes of heated air. These cabinets have been deployed in large numbers in working data centers with actual, measured heat loads in excess of 30 kW per cabinet. Testing has exceeded 30kW per cabinet and there is currently a customer project where cabinets are being shipped into a space where they will be loaded with 30 kW of actual, measured server heat load. Further testing is planned to extend beyond these levels and those reports will be forthcoming.



More important than power density, however, is the customer's costs for cooling these densities, and there is no more efficient, lower cost way of cooling a data center than with the above-described ducted system. The two basic factors affecting this higher efficiency are 100% utilization of HVAC output and an access path to more hours of economization cooling.

With the ducted exhaust system, every bit of cold air produced by the HVAC system has to go through a server – the only path between supply air and return air is one of heat transfer through a server, so there is no waste – there is no bypass and no need for the over-provisioning that is required in standard hot aisle/cold aisle data centers. The efficiency claims of close-coupled and liquid-cooled solutions are based on comparisons to inherently inefficient data centers with a high amount of bypass air, and over-provisioning of cooling necessitated by the extreme variations in pressure and airflow throughout a room. Because of the traditional dependencies on air delivered through proximate perforated access floor tiles, cooling capacity provisioning formulas have had to plan for providing adequate air to the lowest airflow spot in a room, resulting in typically 200-300% over-provisioning, resulting in huge amounts of wasted bypass air. When it no longer matters where the cold air is delivered and when 100% of it must travel through a server, there is no longer a need for that over-provisioning and therefore there is no more waste.

While that elimination of waste may sound like it puts this ducted cabinet solution on an even playing field with the close-coupled and liquid-cooled solutions, it actually puts the ducted approach at an efficiency advantage because of the higher efficiencies of the larger fans and motors moving air at the room level. The coefficient of performance (COP) for the larger motors and fans of the larger free-standing CRAC or CRAH units is always going to be higher than the smaller motors and fans of the close-coupled solutions and the COP of the extremely large water-cooled central air handlers is always going to be superior to anything small enough to fit on the data center floor. This has always been the case, but because of the historical waste of standard hot aisle/cold aisle data centers, this COP advantage never translated into comparable efficiencies on the data center floor. With the ducted cabinet system that results in 100% utilization of the HVAC output, now these superior COP values can be translated directly into data center cooling efficiency.

A further efficiency benefit for the ducted solution arises from chiller plant efficiencies and access to more hours of “free” cooling. In a ducted cabinet data center, there is only one temperature in the data center, so the need to control return air temperature in the typical 72-73°F area to drive a supply temperature in the mid-to-low 50's is no longer required. If the standards allow for 77°F server inlet temperature, then the room can be cooled to 77°F with a 77°F supply air temperature. The higher supply temperatures dramatically improve chiller plant efficiency as well as opening the door for access to significantly more hours of economization cooling. Table 1 describes the temperature thresholds for three different economization strategies.

	Most Data Centers are Here	CRAC w/Economizer TIA 942 Best Practices	CRAC w/ Economizer 100% Isolation	Heat Recover Wheel 100% Isolation	Evaporative Air Economizer 100% Isolation
<b>Delivered</b>	60-85°F	68-77°F	77°F	77°F	77°F
<b>Supply</b>	52-55°F	52-55°F	77°F	77°F	77°F
<b>Water</b>	42°F	42°F	65°F	N / A	65°F
<b>Ambient</b>	37°F	37°F	60°F	72°F	77°F

Table 1: Ambient Temperatures for Economization Operation



With the higher supply temperatures allowed by ducted cabinets, the data center operator first gets the benefits of improved chiller plant efficiency – approximately 1 to 1.5% reduction in chiller plant energy use for every 1 degree increase in the chilled water loop temperature, or 25 to 35% energy use reduction. In addition, these temperatures allow for many more hours of economization cooling – all hours under 60°F for water-side economization; all hours under 72°F for KyotoCooling heat recovery wheel economization and all hours under 77°F wet bulb for evaporative air-side economization. In a data center with a 2.0 Power Utilization Effectiveness (PUE), water side economization and evaporative air-side can reduce the total data center energy use by 35% during those economization hours and by 43% during KyotoCooling hours.

In conclusion, ducted cabinet return air isolation raises the bar by a factor of 4 or 5 for heat densities and provides much more efficient cooling at a lower initial investment than close-coupled or liquid cooled solutions. While a completely contained close-coupled system could provide access to similar water-side economization hours and chiller plant efficiencies, those solutions will, by definition have poorer coefficient of performance ratings and will not be able to provide access to the most economical economization of KyotoCooling nor to the higher number of economization hours of evaporative air-side economization.

