



Tu = 139 LB/SCREW (MAX)Vu = 73 LB/SCREW (MAX)

NOTES:

1. FORCES ARE DETERMINED PER 2010 CALIFORNIA BUILDING CODE AND ASCE 7-05 STRENGTH DESIGN IS USED.

HORIZONTAL FORCE (Eh) = 1.50 Wp (SDS = 2.00, Ap = 2.5, Ip = 1.5, Rp = 6.0, $\mathrm{z/h} \leq$ 1.0) VERTICAL FORCE (Ev) = 0.40 Wp

- 2. CENTER OF GRAVITY (C.G.) WEIGHT IS A MAXIMUM. PRE-APPROVAL ENCOMPASSES ALL WEIGHTS UP TO THE MAXIMUM WEIGHT SHOWN.
- 3. STRUCTURAL ENGINEER OF RECORD SHALL PROVIDE SUPPORT STRUCTURE TO SUPPORT WEIGHTS AND FORCES SHOWN.



EASE EQUIPMENT ANCHORAGE & SEISMIC ENGINEERING www.equipmentanchorage.com						
CHATSWORTH PRODUCTS, INC.		DES. J. ROBERSON		SHEET		
	JOB NO.	JOB NO. 11–1131				
FIXED RACKS (HEAVY DUTY)	DATE	7/6/12	OF	2	SHEETS	

<u>SEISMIC ANCHORAGE</u> <u>WALL MOUNTED</u>

MODEL NO.	"A" (in)	"B" (in)	WEIGHT (lbs)
15320-XI8	40.32"	13.5"	371
* I5320-X24	40.32"	18"	378
15321-XI8	75.32"	13.5"	377
15321-X24	75.32"	18"	380

^{*} MODEL REPRESENTED IN CALCULATION BELOW

LOADS: PER 2010 CALIFORNIA BUILDING CODE AND ASCE 7-05 . (STRENGTH DESIGN IS USED) (SDS = 2.00, 2p = 2.5, 2p = 1.5, 2p =

WEIGHT = 378 LB

HORIZONTAL FORCE (En) = 1.50Wp = 567 LB

VERTICAL FORCE (Ev) = 0.40Wp = 151 LB

BOLT FORCES:

TENSION (T)

$$T_{u \text{ VERTICAL}} = \frac{(1.2(378\#) + 151\#)18"}{8 \text{SCREWS}(31.81")} = 43 \text{ LB}$$

$$T_{u PARALLEL} = \frac{567\#(18")}{8screws(15.24")} = 85 LB$$

$$T_{u PERP.} = \frac{567\#}{16screws} = 35 LB$$

$$T_{u MAX} = 43# + (0.3)(35) + 85 = 139 LB/SCREW (MAX)$$

SHEAR (V)

$$V_{u MAX} = \frac{1.2(378\#) + 151\# + 567\#}{16 \text{ screws}} = 73 \text{ LB/SCREW (MAX)}$$

#12 TEK SCREWS IN 16 GA., 50 KSI STEEL

φT = 328 LB/SCREW

ΦV = 288 LB/SCREW

UNITY CHECK:

$$\left(\frac{\mathsf{T}\,\mathsf{U}}{\mathsf{\Phi}\mathsf{T}}\right) + \left(\frac{\mathsf{V}\,\mathsf{U}}{\mathsf{\Phi}\mathsf{V}}\right) \leq 1.0$$

$$\left(\frac{139}{328}\right) + \left(\frac{73}{288}\right) = 0.68 \le 1.0$$
 ... O.K.